

SOLAR ENERGY CORPORATION OF INDIA LIMITED
NEW DELHI

Ref No. SECI/C&P/IPP/11/0025/24-25/Amendment-02

Date: 02.06.2025

Amendment-02 to Request for Selection (RfS) Document for Selection of Solar Power Developers for Setting up of Grid-Connected Floating Solar PV Projects with Battery Energy Storage System (BESS) in Lakshadweep under RESCO Mode Through Tariff Based Competitive Bidding

RfS No. SECI/C&P/IPP/11/0025/24-25 dated 05.03.2025

S. No.	Clause No.	Existing Clause	Amended Clause																		
RfS Document																					
1.	4	The Table stands modified as follows: <table><tr><th>S. No.</th><th>Name of the Project/ Island</th><th>Project Rated Capacity (MW)</th><th>Solar PV AC Capacity (MW)</th><th>Minimum DC capacity (MWp)</th><th>Minimum BESS Capacity</th></tr><tr><td>1</td><td>Agatti</td><td>1.00</td><td>4.00</td><td>5.20</td><td>3.0 MW, 16 MWh</td></tr><tr><td>2</td><td>Kavaratti</td><td>1.75</td><td>5.00</td><td>6.00</td><td>3.25 MW, 16 MWh</td></tr></table>		S. No.	Name of the Project/ Island	Project Rated Capacity (MW)	Solar PV AC Capacity (MW)	Minimum DC capacity (MWp)	Minimum BESS Capacity	1	Agatti	1.00	4.00	5.20	3.0 MW, 16 MWh	2	Kavaratti	1.75	5.00	6.00	3.25 MW, 16 MWh
S. No.	Name of the Project/ Island	Project Rated Capacity (MW)	Solar PV AC Capacity (MW)	Minimum DC capacity (MWp)	Minimum BESS Capacity																
1	Agatti	1.00	4.00	5.20	3.0 MW, 16 MWh																
2	Kavaratti	1.75	5.00	6.00	3.25 MW, 16 MWh																
2.	Format 7.1	The Table stands modified as follows: <table><tr><th>S. No.</th><th>Name of Project/Island</th><th>Project Capacity* (MW)</th><th>Participation (Yes/No) (No or Blank cell will be assumed as No only)</th></tr><tr><td>1</td><td>Agatti</td><td>1.00</td><td></td></tr><tr><td>2</td><td>Kavaratti</td><td>1.75</td><td></td></tr></table>		S. No.	Name of Project/Island	Project Capacity* (MW)	Participation (Yes/No) (No or Blank cell will be assumed as No only)	1	Agatti	1.00		2	Kavaratti	1.75							
S. No.	Name of Project/Island	Project Capacity* (MW)	Participation (Yes/No) (No or Blank cell will be assumed as No only)																		
1	Agatti	1.00																			
2	Kavaratti	1.75																			
3	Annexure B, Clause 3.1	Project Capacity (MW): 0.95 Minimum BESS capacity: 2.5 MW, 16 MWh (12.8 MWh dispatchable)	Project Capacity (MW): 1.00 Minimum BESS capacity: 3.0 MW, 16 MWh (12.8 MWh dispatchable)																		
4	Annexure B, Clause 3.2	Minimum BESS capacity: 2.5 MW, 16 MWh (12.8 MWh dispatchable)	Minimum BESS capacity: 3.25 MW, 16 MWh (12.8 MWh dispatchable)																		